

# Preliminary Assessment Report

## Project 3024696, 1300 NE 65TH ST

---

**Assessment Completed:** 5/27/2016

**Project Description:** EDG - new construction of a 7-story commercial/residential mixed use building.

**Primary Applicant:** [Jen Lien](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### SDCI Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, [art.richardson@seattle.gov](mailto:art.richardson@seattle.gov)

#### SDCI Land Use Requirements

Malli Anderson, (206) 233-3858, [Malli.Anderson@Seattle.Gov](mailto:Malli.Anderson@Seattle.Gov)

#### SDCI Preapplication Site Visit Requirements

Shomari Anderson, (206) 233-5034, [Shomari.Anderson@seattle.gov](mailto:Shomari.Anderson@seattle.gov)

#### Seattle City Light Requirements

Benjamin Rushwald, (206) 733-9830

#### Seattle Department of Transportation Requirements

Joel Prather, (206) 615-0772, [joel.prather@seattle.gov](mailto:joel.prather@seattle.gov)

#### Seattle Public Utilities Requirements

Steve Resnick, (206) 233-7234, [ResnicS@seattle.gov](mailto:ResnicS@seattle.gov)

#### Water Availability

SPU Staff, (206) 684-3333, [SPUWaterAvailability@Seattle.Gov](mailto:SPUWaterAvailability@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **SDCI Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

**\*\*The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.\*\***

#### **Existing Public Drainage Infrastructure**

Combined sewer main location: **NE 65th St / NE 66th St**

Combined sewer main size: **8-inch / 8-inch**

#### **Drainage**

Infiltration Investigation Required: **Yes**

Projects that require On-site Stormwater Management, Flow Control, and/or Water Quality Treatment must first investigate infiltration feasibility before selecting other BMP's. See Seattle Stormwater Manual, Volume 3, Section 3.2 and Appendix D. If feasible, infiltration testing per the requirements in Appendix D is required prior to application. Submit a completed Infiltration Checklist with the construction permit application. Checklists are available on the DPD Stormwater Code website.

<http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

Please note: projects that infiltrate 5,000 square feet or more of hard surface area must conduct Groundwater Monitoring for a full wet season or one full year if infiltrating 10,000 square feet or more of hard surface area. See Table 3.1 in Section 3.2.

#### **Project Type and Drainage Basin**

The storm drainage point of discharge (SMC 22.805.020) is located at: **Combined sewer** NE 65th St

Project Type: **Parcel-based**

Drainage Basin: **Public combined sewer**

#### **Drainage Control Compliance**

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Parcel-based projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016, 750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater Management** (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.050.B. and Director's Rule 21-2015.

Flow control standards must be first met by utilizing **On-site Stormwater Management** to the maximum extent feasible. Additional flow control measures shall be installed if the flow control standard cannot be met solely using On-site Stormwater Management BMP's.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Flow Control Required: **Peak Flow Control Standard**

This project site discharges to a **Public Combined Sewer** (SMC 805.050.C.5). Based upon the information provided on the Preliminary Application Form pertaining to land disturbing activity and existing and proposed hard surfacing, this project shall provide flow control meeting the **Peak Flow Control Standard** per SMC 22.805.080.B.4. The post-development peak flow with a 4% annual probability (25-year recurrence flow) shall not exceed 0.4 cubic feet per second per acre. Additionally, the peak flow with a 50% annual probability (2-year recurrence flow) shall not exceed 0.15 cubic feet per second per acre.

Projects with less than 10,000 sf new plus replaced hard surface can use the [Pre-Sized Flow Control Calculator](#) in lieu of continuous modeling.

### **Water Quality**

No requirements

### **Wastewater**

The wastewater point of discharge (SMC 21.16.070.B) is located at **NE 65th St.**

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

### **Permanent and Temporary Dewatering**

Per SMC 21.16.110, the proposed project requires a separate side sewer permit for temporary dewatering based on the following: excavation greater than 12 feet deep.

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: **Combined system.**

### **Side Sewer**

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

If there is an increase of dwelling units or buildings the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

For your information:

In serving establishments (i.e restaurants, cafes, lunch counters, cafeterias, bars and clubs, hotels, hospitals, sanitariums, factory or school kitchens, or other establishments where grease is introduced into the drainage or sewage system), there may be additional requirements to control the discharge of fats, oils, and grease (FOG) into the sanitary sewer system.

Please contact: [Gary.Christiansen@seattle.gov](mailto:Gary.Christiansen@seattle.gov) in SPU's FOG Program to determine pretreatment requirements to protect the municipal sewer system from FOG generated by food preparation and handling.

Any internal plumbing modifications require a plumbing permit from King County Public Health 206-684-5198.

For more information, visit:

<http://www.seattle.gov/util/MyServices/DrainageSewer/FatsOilsGrease/index.htm>

<http://www.kingcounty.gov/healthservices/health/ehs/foodsafety/FoodBusiness.aspx>

## **SDCI Land Use Code Requirements**

### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

#### **NE 65TH ST**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Existing curbcuts that will no longer be used are required to be removed, and the curblin installed, per SDOT standards.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

#### **NE 66TH ST**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Existing curbcuts that will no longer be used are required to be removed, and the curblin installed, per SDOT standards.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

#### **BROOKLYN AVE NE**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Existing curbcuts that will no longer be used are required to be removed, and the curblin installed, per SDOT standards.

Any planting proposed within the ROW must be reviewed and approved by DPD and SDOT.

### **Land Use**

Based on the project scope. SEPA may be required. See DPD Director's Rule 29-2015 for more details (<http://web1.seattle.gov/dpd/dirrulesviewer/>).

Design Review is required; see CAM 238 for more details. Departures from development standards should be identified as early as possible in the application process.

An arborist report may be required. See CAM 242 for more detail.

**Design Review Alert Residential** For three or more attached or detached dwelling units, Design Review may be required if abutting a qualifying lot and the combined total of development exceeds the design review thresholds in SMC 23.41.004 Table A or B, at the time application is made. Please see SMC 23.41.004.A.8 in Ordinance 124843 effective 9/21/2015.

### **Other Requirements**

A presubmittal conference is required before submitting an application. Details for preparing and submitting a presubmittal request form can be found at our Web site

([http://www.seattle.gov/dpd/Publications/Forms/Building\\_Permit/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp)).

## **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the SDCI Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by SDCI within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

See notes below.

### **ECA Mapping Unit and Type**

Non-ECA

### **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

### **Existing ROW Conditions**

#### **NE 65TH ST**

Street conditions:

Asphalt paving

Visible pavement width is: 47 lf

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 6 in inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

#### **NE 66TH ST**

Street conditions:

Concrete paving

Visible pavement width is: 20 LF

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5 in inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

#### **BROOKLYN AVE NE**

Street conditions:

Concrete paving

Visible pavement width is: 18 LF

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5 in inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

### **Potential Impacts to Seattle Parks Property**

No parks property in vicinity

### **Tree Protection**

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

### **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

### **Inspectors Notes**

Several trees onsite that are of good size, that should be addressed and placed on proposed plans.

## **Seattle City Light Requirements**

### **Street/Alley Requirements**

#### **NE 65TH ST**

Clearance from Structures: Fourteen (14) feet radial clearance is required between power lines and any part of the permanent structure per Seattle City Light Construction Standard D2-3 (<http://www.seattle.gov/light/engstd/docs2/d2-3.pdf>). Transmission lines require greater clearance. Changes to SCL's system to meet clearances are done at the project's expense. overhead 26 kV high voltage powerlines

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This City Light work is done at the project's expense. City Light may not be able to grant customer requests to temporarily relocate or de-energize the distribution system.

Based on our assessment of the size of your project, you may need transformers on your private property for power service to your building. This can be done with vaults inside the building, below-grade vaults, or

above-grade pads exterior to the building. Include these facilities for your project power needs in your building plans. SCL has access, clearance, size and location requirements for vaults. Some transformers require long lead times to obtain. Contact SCL well in advance to provide electrical service size and voltage details.

## **NE 66TH ST**

**Clearance from Structures:** Fourteen (14) feet radial clearance is required between power lines and any part of the permanent structure per Seattle City Light Construction Standard D2-3 (<http://www.seattle.gov/light/engstd/docs2/d2-3.pdf>). Transmission lines require greater clearance. Changes to SCL's system to meet clearances are done at the project's expense. overhead 26 kV high voltage powerlines

**Working Clearance:** State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This City Light work is done at the project's expense. City Light may not be able to grant customer requests to temporarily relocate or de-energize the distribution system.

## **Conservation**

**Built Smart Programs** - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. From insulation and windows to lighting and appliances, take advantage of new technologies and construct a more efficient building with our help. For more information: contact Phoebe Warren at (206)684-3795 or [phoebe.warren@seattle.gov](mailto:phoebe.warren@seattle.gov).

## **Notes to Applicant**

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Dave Kylen, 206-615-0607, [david.kylen@seattle.gov](mailto:david.kylen@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

## **SDOT Permitting Information**

Initial Review Deposit: To be determined

SDOT Plan Requirements: Plan

SDOT Permit Requirements: Group 1:Over-the-Counter. Obtain from SDOT anytime prior to construction in the right of way.

All private encroachments in the public right-of-way (ROW) require a 30-day permit that is renewed annually.

Based on the scope of your project and the proximity to the lot line a SIP may be triggered by the extent of construction impacts to existing street, sidewalk or alley improvements. If more than 2,000 sf of impervious surface in the right of way will be replaced a SIP will be required.

A drainage review is required as part of the Street Use Permit if more than 750 square feet of land disturbing activity will take place in the right of way.

## **Street Improvement Requirements**

### **NE 65TH ST**

**Tree protection:** Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees. Coordinate with SDOT UF for evaluation all existing ROW trees & recommendations.



Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement. 5' min planting strip

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

ROW setback to st grade

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Relocation 6' std sw for 5'pl strip & std st tree location; public sidewalk easement as needed.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410. Construct new curb & restoration @ existing drwy closures.

New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards. Construct new drwy per SDCI permit & COS std plan 430A.

New/replacement curb ramps: See City's Standard Plans 422 and the current ADA requirements.

## **NE 66TH ST**

Tree protection: Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees. Coordinate with SDOT UF for evaluation all existing ROW trees & recommendations.

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement. Coordinate with SDOT UF.

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Repair & restoration of existing as needed.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410. Construct new curb & restoration @ existing drwy closures.

New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards. Construct new drwys per SDCI permit & COS std plan 430A.

New/replacement curb ramps: See City's Standard Plans 422 and the current ADA requirements.

## **BROOKLYN AVE NE**

Tree protection: Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees. Coordinate with SDOT UF for evaluation all existing ROW trees & recommendations.

Tree planting. See Seattle Right of Way Improvements Manual (ROWIM) and City of Seattle Standard Plans 030, 100 and 424. Contact SDOT Urban Forestry for residential projects at (206) 684-TREE; for all others at (206) 684-5693 for approval of species and placement. Coordinate with SDOT UF.

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Repair & restoration of existing as needed.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410. Construct new curb & restoration @ existing drwy closures.



New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards. Construct new drwys per SDCI permit & COS std plan 430A.

New/replacement curb ramps: See City's Standard Plans 422 and the current ADA requirements.

Other requirements: Recommend comprehensive SIP review process.

### Discretionary ROW Improvements

Street Lighting, Pedestrian Lighting, and Traffic Signal revisions: See ROWIM Chapter 4.

The project is located within the boundaries of plan. Contact SDOT for specific plan information.

### Construction Management Plan

If your project is mid- or large-size and will significantly impact the right of way, a Construction Management Plan (CMP) is required to be submitted to [sdotpermits@seattle.gov](mailto:sdotpermits@seattle.gov) two to three months prior to obtaining Construction Use Permits or any other Street Use Permits. Upon receipt of the CMP, Street Use Permit Applicant Services will contact you to set up a pre-submittal meeting to discuss Street Use permitting requirements and your CMP.

For information on what is required to be in your CMP go to <http://www.seattle.gov/transportation/cmp.htm>.

## SPU Requirements

### Flow Control Compliance

Soil Amendment. Retain and protect undisturbed soil in areas not being developed, and prior to completion of the project, amend all new, replaced, and disturbed topsoil (including construction lay-down areas) with organic matter to the extent required by and in compliance with the rules promulgated by the Director.

On-site Stormwater Management. All trail and sidewalk projects with 2,000 square feet or more of new plus replaced hard surface or 7,000 square feet or more of land disturbing activity shall meet the Minimum Requirements for On-site Stormwater Management contained in Section 22.805.070, to the extent allowed by law.

### Water Availability

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20160638

Water Availability Certificate status: Approved with No Changes

Prepared by: Michael Barrett

### Existing Water System Information

Proximity of nearest fire hydrant is: 241 feet E of property. Meets standards.

Water Main:

Size: 8 inches

Material: Cast Iron

Class: C

- Standard

- Abutting

Water Main is available to serve in: NE 65th Street

Distance of main to N margin of street is 23 feet.

Public ROW width is 63 feet.

Water Service(s):

Size: 3/4"

Material: Galvanized Iron

Size: 3/4"

Material: Galvanized Iron

Size: 3/4"

Material: Copper

Size: 3/4"

Material: Galvanized Iron

Size: 3/4"

Material: Copper

## Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).